



CALDWELL COUNTY FIRE INSPECTION REPORT

616 West Avenue, NW
Po Box 2200
Lenoir, North Carolina 28645
(828) 757-1277



Name: OLD SHUFORD MILL BUILDING 10-B

Date: 7-19-17

Physical Location: 10-B FALLS AVE

Class: F1/S1 Occupancy: _____

Mailing Address: _____

Fire District: GRANITE FALLS

City: GRANITE FALLS State: NC Zip: 28630

City Limits: _____

Contact: MIKE GRANGER

Phone: _____

Type of Inspection

☒ General Use ☐ New Occupancy ☐ Change of Occupancy ☐ Special Use
☐ Fire Alarm ☐ Fire Suppression ☐ Re-Inspection ☐ Other

Violation Summary

Your attention is called to the violations to the Fire Prevention Code that exist at the above address. You are hereby notified to remedy the conditions as stated or show cause why you should not be required to do so.

Type of Violation or Hazard:

- *- REPAIR SPRINKLER SYSTEM ASAP! (PUT BACK IN SERVICE)
 - *- PROVIDE 24 HOUR FIRE WATCH - WALKING GROUNDS EVERY
HOUR AND DOCUMENTING UNTIL SPRINKLER SYSTEM BACK ONLINE.
 - PROVIDE COVERS ON ALL ELECTRICAL PANELS + JUNCTION BOXES.
 - REPAIR NON-WORKING EXIT + EMERGENCY LIGHTING THROUGHOUT!
 - MOUNT EXISTING FIRE EXTINGUISHERS.
 - ADD EXTINGUISHERS SO THERE IS NOT MORE THAN 75' OF TRAVEL
DISTANCE BETWEEN EXTINGUISHERS.
- (WILL RE-INSPECT 7-24-17)

☐ Violations must be corrected in 30 Days.

☒ Violations must be corrected immediately.

Signed Mike Granger Fire Marshal

Page 1 of 1

I certify that the above listed violations have been explained to me and that I understand that I am required to correct these violations in accordance of applicable state and local Laws and Regulations, and comply with all permit requirements.

Signed _____ Print Name _____ Date _____

*** PLEASE NOTE ***

WHITE COPY RETAINED BY FIRE MARSHAL'S OFFICE AT TIME OF INSPECTION. YELLOW AND PINK COPY TO OCCUPANT. WHEN VIOLATIONS OR HAZARDS HAVE BEEN CORRECTED, SIGN PINK COPY. KEEP YELLOW COPY FOR YOUR RECORDS AND SEND THE PINK COPY TO THE FIRE MARSHAL'S OFFICE. (PO BOX LISTED ABOVE OR FAX TO (828) 757-1182). IF NOT RETURNED A RE-INSPECTION WILL BE SCHEDULED.

I hereby certify that the above violations or Hazards have been corrected.